



NOTES

1. Min conductors size 16mm. Max size 35mm.
2. Neutral and earth cable size to same as line conductors size.
3. Use boot lace connectors on all Line and Neutral terminations.
4. Do not daisy chain earth conductors to load. Use a separate earth conductor from main earth to SPD3200.
5. Do not megger test this device. It contains voltage limiting components. Megger testing may cause damage to the unit unless MCB is in the off position. Do not megger between Neutral and Earth.

01	First release		07/02/2013	MH	DO NOT SCALE	DRAWN: MH	EATON	EATON POWER QUALITY PTY LTD	SPD3200-TN-E. Connection diagram
FIRST PRODUCTION ISSUE					ALL DIMENSIONS ARE IN MILLIMETERS	DATE: 07/02/2013	Powerware	© 2007	TVSS 55SPD3200 connect
					GENERAL TOLERANCE	CHECK:	ABN 82 054 056 709	2-8 Kent Road	Oracle # SPD3200-TN-E
REV	CHANGE	ECO No	DATE	BY	UNLESS OTHERWISE STATED	APPR:	MASCOT 2020	SCALE: NTS	SHEET: 1 OF 1
1	2	3	4	5	6	7	8	A3	A3